



STATE OF NORTH CAROLINA  
DEPARTMENT OF TRANSPORTATION

PAT MCCRORY  
GOVERNOR

NICHOLAS J. TENNYSON  
SECRETARY

August 14, 2015

ADDENDUM # 1

To: Plan Holders

From: Jeffrey E. Alsbaugh  
Proposal Engineer

DS  
jea

RE: **Questions & Answers**  
Contract ID: DN00377  
County: Graham  
Letting Date: August 25, 2015

The following questions were posed by a bidder:

1. Can you advise the size of the wood supports for Bid Item 0007 for this project?
2. Also, can you provide the grade of lumber and preservative treatment for the wood?

The following corresponding answers were provided:

1. 4"x6"
2. On the grade and preservative treatment of the wood, reference standard specifications 1082-3 and 1082-4.

This Q&A resulted in no change to the bid items or their associated quantities, therefore there is no updated ebs file associated with this addendum.

Please insert this letter into the addendum section of the proposal and sign the verification. Thank you for your attention to this matter.